



FIRE FLOW REQUIREMENTS

COMMERCIAL BUILDINGS

0-4,999 sq. ft. and above

Minimum – One fire hydrant, or automatic fire alarm system or fire sprinkler system

5000 sq. ft. and above

Minimum – All of the following:

One fire hydrant, automatic fire alarm system, automatic fire sprinkler system

EXCEPTION:

The following occupancies shall be sprinkled:

Assembly occupancies with an occupant load of 300 or more

A-2 occupancies with an occupant load of 100 or more

Woodworking/cabinet shops 2,500 square feet and above

All Group E occupancies

Commercial buildings more than 2 stories in height, including basement

Repair garages 3000 square feet and above with open flame or welding

RESIDENTIAL CONSTRUCTION

Residences 5000 sq. ft. and above, automatic fire sprinkler system required.

Residences that are three stories or higher, automatic fire sprinkler system required.

**THIS MAY NOT BE ALL INCLUSIVE.
PLEASE CONTACT CENTRAL YAVAPAI FIRE DISTRICT
FOR MORE INFORMATION
928/759-9933**